

# PORTABLE APPLIANCE TESTING (PAT) REPORT/CERTIFICATE

Original Certificate
Certificate

**DETAILS OF CLIENT/LANDLORD**

**Client/Address:** Otter Pool barn, West Stowford Barton, EX34 8PJ

**TEST EQUIPMENT DETAILS**

**Test Equipment used** Seaward Primetest 100      **Serial Number** 00012442378

**Tested by** S BROOKES      **Date** 12/6/2024      **Retest Date** 12/6/2025

Serial Number	Type	Location	Class	Fuse (A)	Insulation	Earth	Plug, flex and body	Pass Fail
1	Kettle	Kitchen	2	13	Y	N/A	Y	P
2	Toaster	Kitchen	1	13	Y	Y	Y	P
3	Coffee machine	Kitchen	2	13	Y	N/A	Y	P
4	Hand mixer	Kitchen	2	3	Y	N/A	Y	P
5	Hand mixer	Kitchen	2	3	Y	N/A	Y	P
6	Micro wave	Kitchen	1	13	Y	Y	Y	P
7	Torch	Kitchen	1	3	Y	Y	Y	P
8	Fan	Snug	2	3		N/A	Y	P
9	Hand grill	Kitchen	1	13	Y	Y	Y	P
10	Hoist cable	Snug	1	6	Y	Y	Y	P
11	Hoist	Snug	1	6	Y	Y	Y	P
12	Lamp	Snug	2	3	Y	N/A	Y	P
13	Chair	Snug	2	3	Y	N/A	Y	P
14	Lamp	Snug	2	3	Y	N/A	Y	P
15	Heater/fire	Snug	2	13	Y	N/A	Y	P
16	TV	Snug	2	3	Y	N/A	Y	P
17	Sat box	Snug	1	3	Y	Y	Y	P
18	T-Loop	Snug	1	3	Y	Y	Y	P
19	DVD	Snug	2	3	Y	N/A	Y	P
20	Radio	Hall	2	3	Y	N/A	Y	P
21	Lamp	Hall	2	3	Y	N/A	Y	P
22	Chair	Hall	2	3	Y	N/A	Y	P
23	Pump	Hall	2	6	Y	N/A	Y	P
24	Pump	Hall	2	6	Y	N/A	Y	P

# PORTABLE APPLIANCE TESTING (PAT) REPORT/CERTIFICATE

Original Certificate
Certificate

**DETAILS OF CLIENT/LANDLORD**

Client/Address: Otter Pool barn, West Stowford Barton, EX34 8PJ

**TEST EQUIPMENT DETAILS**

Test Equipment used Seaward Primetest 100 Serial Number 00012442378

Tested by S BROOKES Date 12/6/2024 Retest Date 12/6/2025

Serial Number	Type	Location	Class	Fuse (A)	Insulation	Earth	Plug, flex and body	Pass Fail
25	Lamp	Hall	2	3	Y	N/A	Y	P
26	Lamp	Bed 1	2	3	Y	N/A	Y	P
27	Lamp	Bed 1	2	3	Y	N/A	Y	P
28	Bed	Bed 1	2	6	Y	N/A	Y	P
29	Bed	Bed 1	2	6	Y	N/A	Y	P
30	TV	Bed 1	2	3	Y	N/A	Y	P
31	TV	Bed 2	2	3	Y	N/A	Y	P
32	Hoist lead	Passage	2	6	Y	N/A	Y	P
33	Hoist	Passage	2	6	Y	N/A	Y	P
34	TV	Bed 3	2	3	Y	N/A	Y	P
35	TV	Bed 4	2	3	Y	N/A	Y	P
36	Bed	Bed 4	2	3	Y	N/A	Y	P
37	TV	Bed 5	2	3	Y	N/A	Y	P
38	Bed	Bed 5	2	3	Y	N/A	Y	P
39	TV	Bed 6	2	3	Y	N/A	Y	P
40	Light Xmas	Hall	2	None	Y	N/A	Y	P
41	Xmas X-lead	Hall	1	10	Y	Y	Y	P
42	Lights Xmas	Hall	2	None	Y	N/A	Y	P

--	--	--	--	--	--	--	--	--